



District of Columbia International School - Lead in Water Test Results



FY20 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
District of Columbia International School	WS-016-001	Food Prep Sink	Ground	In kitchen			WF-072019-016001-02	11/15/2019	FT-FY20-072019-016001-A	<1	FT-FY20-072019-016001-B	<1
District of Columbia International School	WS-016-002	Cooler	Ground	In hallway adjacent to room GB22	Low	Left	WF-072019-016002-02	11/15/2019	FT-FY20-072019-016002-A	<1	FT-FY20-072019-016002-B	<1
District of Columbia International School	WS-016-004	Cooler	Ground	In hallway adjacent to room GB22	High	Right	WF-072019-016004-02	11/15/2019	FT-FY20-072019-016004-A	<1	FT-FY20-072019-016004-B	<1
District of Columbia International School	WS-016-005	Cooler	Ground	In hallway adjacent to girls' restroom	Low	Left	WF-072019-016005-02	11/15/2019	FT-FY20-072019-016005-A	<1	FT-FY20-072019-016005-B	<1
District of Columbia International School	WS-016-006	Bottle Filler	Ground	In hallway adjacent to girls' restroom	High	Left	WF-072019-016006-02	11/15/2019	FT-FY20-072019-016006-A	<1	FT-FY20-072019-016006-B	<1
District of Columbia International School	WS-016-007	Cooler	Ground	In hallway adjacent to girls' restroom	High	Left	WF-072019-016007-02	11/15/2019	FT-FY20-072019-016007-A	<1	FT-FY20-072019-016007-B	<1
District of Columbia International School	WS-016-008	Break Room	Ground	In break room GA64			WF-072019-016008-02	11/15/2019	FT-FY20-072019-016008-A	<1	FT-FY20-072019-016008-B	<1
District of Columbia International School	WS-016-009	Cooler	1	In hallway adjacent to staff restroom	Low	Left	WF-072019-016009-02	11/15/2019	FT-FY20-072019-016009-A	<1	FT-FY20-072019-016009-B	<1
District of Columbia International School	WS-016-010	Bottle Filler	1	In hallway adjacent to staff restroom	High	Left	WF-072019-016010-02	11/15/2019	FT-FY20-072019-016010-A	<1	FT-FY20-072019-016010-B	<1
District of Columbia International School	WS-016-011	Cooler	1	In hallway adjacent to staff restroom	High	Right	WF-072019-016011-02	11/15/2019	FT-FY20-072019-016011-A	<1	FT-FY20-072019-016011-B	<1
District of Columbia International School	WS-016-012	Break Room	1	In break room 1C02			WF-072019-016012-02	11/15/2019	FT-FY20-072019-016012-A	<1	FT-FY20-072019-016012-B	<1
District of Columbia International School	WS-016-013	Cooler	2	In hallway adjacent to boys' restroom	Low	Left	WF-072019-016013-02	11/15/2019	FT-FY20-072019-016013-A	<1	FT-FY20-072019-016013-B	<1
District of Columbia International School	WS-016-014	Bottle Filler	2	In hallway adjacent to boys' restroom	High	Left	WF-072019-016014-02	11/15/2019	FT-FY20-072019-016014-A	<1	FT-FY20-072019-016014-B	<1
District of Columbia International School	WS-016-015	Cooler	2	In hallway adjacent to boys' restroom	High	Right	WF-072019-016015-02	11/15/2019	FT-FY20-072019-016015-A	<1	FT-FY20-072019-016015-B	<1
District of Columbia International School	WS-016-016	Break Room	2	In break room 2B02			WF-072019-016016-02	11/15/2019	FT-FY20-072019-016016-A	<1	FT-FY20-072019-016016-B	<1
District of Columbia International School	WS-016-017	Cooler	3	In hallway adjacent to room 3B13	Low	Left	WF-072019-016017-02	11/15/2019	FT-FY20-072019-016017-A	<1	FT-FY20-072019-016017-B	<1
District of Columbia International School	WS-016-018	Bottle Filler	3	In hallway adjacent to room 3B13	Low	Left	WF-072019-016018-02	11/15/2019	FT-FY20-072019-016018-A	<1	FT-FY20-072019-016018-B	<1
District of Columbia International School	WS-016-019	Cooler	3	In hallway adjacent to room 3B13	High	Right	WF-072019-016019-02	11/15/2019	FT-FY20-072019-016019-A	<1	FT-FY20-072019-016019-B	<1
District of Columbia International School	WS-016-020	Health Suite	Ground	In health suite GB22			WF-072019-016020-02	11/15/2019	FT-FY20-072019-016020-A	<1	FT-FY20-072019-016020-B	<1
District of Columbia International School	WS-016-022	Cooler	2	In hallway adjacent to room 2C22	Low	Left	WF-072019-016022-01	11/15/2019	FT-FY20-072019-016022-A	<1	FT-FY20-072019-016022-B	<1
District of Columbia International School	WS-016-023	Cooler	2	In hallway adjacent to room 2C22	High	Right	WF-072019-016023-01	11/15/2019	FT-FY20-072019-016023-A	<1	FT-FY20-072019-016023-B	<1
District of Columbia International School	WS-016-024	Bottle Filler	1	In hallway adjacent to 1C25			WF-072019-016024-01	11/15/2019	FT-FY20-072019-016024-A	<1	FT-FY20-072019-016024-B	<1
District of Columbia International School	WS-016-025	Cooler	1	In hallway adjacent to 1C25	Low	Left	WF-072019-016025-01	11/15/2019	FT-FY20-072019-016025-A	<1	FT-FY20-072019-016025-B	<1
District of Columbia International School	WS-016-026	Cooler	1	In hallway adjacent to 1C25	High	Right	WF-072019-016026-01	11/15/2019	FT-FY20-072019-016026-A	<1	FT-FY20-072019-016026-B	<1
District of Columbia International School	WS-016-027	Bottle Filler	1	In gym			WF-072019-016027-01	11/15/2019	FT-FY20-072019-016027-A	<1	FT-FY20-072019-016027-B	<1
District of Columbia International School	WS-016-028	Cooler	1	In gym	Low	Left	WF-072019-016028-01	11/15/2019	FT-FY20-072019-016028-A	<1	FT-FY20-072019-016028-B	<1
District of Columbia International School	WS-016-029	Cooler	1	In gym	High	Right	WF-072019-016029-01	11/15/2019	FT-FY20-072019-016029-A	<1	FT-FY20-072019-016029-B	<1