



District of Columbia International School - Lead in Water Test Results



FY25 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
District of Columbia International School	WS-016-001	Food Prep Sink	Ground	In kitchen			WF-012025-016001-08	6/23/2025	FT-FY25-012025-016001-A	<1	FT-FY25-012025-016001-B	<1
District of Columbia International School	WS-016-002	Cooler	Ground	In hallway adjacent to room GB22	Low	Left	WF-012025-016002-10	6/23/2025	FT-FY25-012025-016002-A	<1	FT-FY25-012025-016002-B	<1
District of Columbia International School	WS-016-003	Bottle Filler	Ground	In hallway adjacent to room GB22	High	Left	WF-012025-016003-10	6/23/2025	FT-FY25-012025-016003-A	<1	FT-FY25-012025-016003-B	<1
District of Columbia International School	WS-016-004	Cooler	Ground	In hallway adjacent to room GB22	High	Right	WF-012025-016004-10	6/23/2025	FT-FY25-012025-016004-A	<1	FT-FY25-012025-016004-B	<1
District of Columbia International School	WS-016-005	Cooler	Ground	In hallway adjacent to girls' restroom	Low	Left	WF-012025-016005-10	N/A	FT-FY25-012025-016005-A	Non-operational	FT-FY25-012025-016005-B	Non-operational
District of Columbia International School	WS-016-006	Bottle Filler	Ground	In hallway adjacent to girls' restroom	High	Left	WF-012025-016006-10	6/23/2025	FT-FY25-012025-016006-A	<1	FT-FY25-012025-016006-B	<1
District of Columbia International School	WS-016-007	Cooler	Ground	In hallway adjacent to girls' restroom	High	Left	WF-012025-016007-10	N/A	FT-FY25-012025-016007-A	Non-operational	FT-FY25-012025-016007-B	Non-operational
District of Columbia International School	WS-016-008	Break Room	Ground	In break room GA64			WF-012025-016008-08	6/23/2025	FT-FY25-012025-016008-A	<1	FT-FY25-012025-016008-B	<1
District of Columbia International School	WS-016-009	Cooler	1	In hallway adjacent to staff restroom	Low	Left	WF-012025-016009-10	6/23/2025	FT-FY25-012025-016009-A	<1	FT-FY25-012025-016009-B	<1
District of Columbia International School	WS-016-010	Bottle Filler	1	In hallway adjacent to staff restroom	High	Left	WF-012025-016010-10	6/23/2025	FT-FY25-012025-016010-A	<1	FT-FY25-012025-016010-B	<1
District of Columbia International School	WS-016-011	Cooler	1	In hallway adjacent to staff restroom	High	Right	WF-012025-016011-10	N/A	FT-FY25-012025-016011-A	Non-operational	FT-FY25-012025-016011-B	Non-operational
District of Columbia International School	WS-016-012	Break Room	1	In break room 1C02			WF-012025-016012-08	N/A	FT-FY25-012025-016012-A	Non-operational	FT-FY25-012025-016012-B	Non-operational
District of Columbia International School	WS-016-013	Cooler	2	In hallway adjacent to boys' restroom	Low	Left	WF-012025-016013-10	6/23/2025	FT-FY25-012025-016013-A	<1	FT-FY25-012025-016013-B	<1
District of Columbia International School	WS-016-014	Bottle Filler	2	In hallway adjacent to boys' restroom	High	Left	WF-012025-016014-10	6/23/2025	FT-FY25-012025-016014-A	<1	FT-FY25-012025-016014-B	<1
District of Columbia International School	WS-016-015	Cooler	2	In hallway adjacent to boys' restroom	High	Right	WF-012025-016015-10	6/23/2025	FT-FY25-012025-016015-A	<1	FT-FY25-012025-016015-B	<1
District of Columbia International School	WS-016-017	Cooler	3	In hallway adjacent to room 3B13	Low	Left	WF-012025-016017-09	6/23/2025	FT-FY25-012025-016017-A	<1	FT-FY25-012025-016017-B	<1
District of Columbia International School	WS-016-018	Bottle Filler	3	In hallway adjacent to room 3B13	Low	Left	WF-012025-016018-09	6/23/2025	FT-FY25-012025-016018-A	<1	FT-FY25-012025-016018-B	<1
District of Columbia International School	WS-016-019	Cooler	3	In hallway adjacent to room 3B13	High	Right	WF-012025-016019-09	6/23/2025	FT-FY25-012025-016019-A	<1	FT-FY25-012025-016019-B	<1
District of Columbia International School	WS-016-020	Health Suite	Ground	In health suite GB22			WF-012025-016020-08	6/23/2025	FT-FY25-012025-016020-A	<1	FT-FY25-012025-016020-B	<1
District of Columbia International School	WS-016-021	Bottle Filler	2	In hallway adjacent to room 2C22			WF-012025-016021-08	N/A	FT-FY25-012025-016021-A	Non-operational	FT-FY25-012025-016021-B	Non-operational
District of Columbia International School	WS-016-022	Cooler	2	In hallway adjacent to room 2C22	Low	Left	WF-012025-016022-08	6/23/2025	FT-FY25-012025-016022-A	<1	FT-FY25-012025-016022-B	<1
District of Columbia International School	WS-016-023	Cooler	2	In hallway adjacent to room 2C22	High	Right	WF-012025-016023-08	6/23/2025	FT-FY25-012025-016023-A	<1	FT-FY25-012025-016023-B	<1
District of Columbia International School	WS-016-024	Bottle Filler	1	In hallway adjacent to 1C25			WF-012025-016024-07	6/23/2025	FT-FY25-012025-016024-A	<1	FT-FY25-012025-016024-B	<1
District of Columbia International School	WS-016-025	Cooler	1	In hallway adjacent to 1C25	Low	Left	WF-012025-016025-07	N/A	FT-FY25-012025-016025-A	Non-operational	FT-FY25-012025-016025-B	Non-operational
District of Columbia International School	WS-016-026	Cooler	1	In hallway adjacent to 1C25	High	Right	WF-012025-016026-07	6/23/2025	FT-FY25-012025-016026-A	<1	FT-FY25-012025-016026-B	<1
District of Columbia International School	WS-016-027	Bottle Filler	1	In gym			WF-012025-016027-10	6/23/2025	FT-FY25-012025-016027-A	<1	FT-FY25-012025-016027-B	<1
District of Columbia International School	WS-016-028	Cooler	1	In gym	Low	Left	WF-012025-016028-10	6/23/2025	FT-FY25-012025-016028-A	<1	FT-FY25-012025-016028-B	<1
District of Columbia International School	WS-016-029	Cooler	1	In gym	High	Right	WF-012025-016029-10	6/23/2025	FT-FY25-012025-016029-A	<1	FT-FY25-012025-016029-B	<1
District of Columbia International School	WS-016-030	Break Room	Ground	In staff lounge GD10			WF-012025-016030-07	N/A	FT-FY25-012025-016030-A	Non-operational	FT-FY25-012025-016030-B	Non-operational
District of Columbia International School	WS-016-031	Cooler	Ground	In hallway adjacent to GD10	Low	Left	WF-012025-016031-07	N/A	FT-FY25-012025-016031-A	Non-operational	FT-FY25-012025-016031-B	Non-operational
District of Columbia International School	WS-016-032	Cooler	Ground	In hallway adjacent to GD10	High	Right	WF-012025-016032-07	6/23/2025	FT-FY25-012025-016032-A	<1	FT-FY25-012025-016032-B	<1
District of Columbia International School	WS-016-033	Bottle Filler	Ground	In hallway adjacent to GD10			WF-012025-016033-07	6/23/2025	FT-FY25-012025-016033-A	<1	FT-FY25-012025-016033-B	<1
District of Columbia International School	WS-016-072	Break Room	1	In room 1A62			WF-012025-016072-02	6/23/2025	FT-FY25-012025-016072-A	<1	FT-FY25-012025-016072-B	<1
District of Columbia International School	WS-016-073	Break Room	2	In room 2C14			WF-012025-016073-02	6/23/2025	FT-FY25-012025-016073-A	<1	FT-FY25-012025-016073-B	<1
District of Columbia International School	WS-040-001	Cooler	Ground	In hallway adjacent to room GA14	Low	Left	WF-012025-040001-10	6/23/2025	FT-FY25-012025-040001-A	<1	FT-FY25-012025-040001-B	<1
District of Columbia International School	WS-040-002	Bottle Filler	Ground	In hallway adjacent to room GA14			WF-012025-040002-10	6/23/2025	FT-FY25-012025-040002-A	<1	FT-FY25-012025-040002-B	<1
District of Columbia International School	WS-040-003	Cooler	Ground	In hallway adjacent to room GA14	High	Right	WF-012025-040003-10	6/23/2025	FT-FY25-012025-040003-A	<1	FT-FY25-012025-040003-B	<1
District of Columbia International School	WS-040-006	Classroom Faucet	Ground	In classroom GA12			WF-012025-040006-09	6/23/2025	FT-FY25-012025-040006-A	<1	FT-FY25-012025-040006-B	<1
District of Columbia International School	WS-040-008	Classroom Faucet	Ground	In classroom GA11			WF-012025-040008-10	N/A	FT-FY25-012025-040008-A	Non-operational	FT-FY25-012025-040008-B	Non-operational
District of Columbia International School	WS-040-010	Health Suite	Ground	In health suite GA06			WF-012025-040010-09	6/23/2025	FT-FY25-012025-040010-A	<1	FT-FY25-012025-040010-B	<1
District of Columbia International School	WS-040-011	Classroom Faucet	1	In classroom 1A11			WF-012025-040011-09	6/23/2025	FT-FY25-012025-040011-A	2.72	FT-FY25-012025-040011-B	<1
District of Columbia International School	WS-040-013	Classroom Faucet	1	In classroom 1A12			WF-012025-040013-09	6/23/2025	FT-FY25-012025-040013-A	1.3	FT-FY25-012025-040013-B	<1
District of Columbia International School	WS-040-017	Cooler	1	In hallway adjacent to room 1A14	Low	Left	WF-012025-040017-09	6/23/2025	FT-FY25-012025-040017-A	<1	FT-FY25-012025-040017-B	<1
District of Columbia International School	WS-040-018	Bottle Filler	1	In hallway adjacent to room 1A14			WF-012025-040018-09	6/23/2025	FT-FY25-012025-040018-A	<1	FT-FY25-012025-040018-B	<1
District of Columbia International School	WS-040-019	Cooler	1	In hallway adjacent to room 1A14	Low	Right	WF-012025-040019-09	N/A	FT-FY25-012025-040019-A	Non-operational	FT-FY25-012025-040019-B	Non-operational
District of Columbia International School	WS-040-020	Cooler	2	In hallway adjacent to room 2A14	Low	Left	WF-012025-040020-10	6/23/2025	FT-FY25-012025-040020-A	<1	FT-FY25-012025-040020-B	<1
District of Columbia International School	WS-040-021	Bottle Filler	2	In hallway adjacent to room 2A14			WF-012025-040021-09	6/23/2025	FT-FY25-012025-040021-A	<1	FT-FY25-012025-040021-B	<1
District of Columbia International School	WS-040-022	Cooler	2	In hallway adjacent to room 2A14	High	Right	WF-012025-040022-09	6/23/2025	FT-FY25-012025-040022-A	<1	FT-FY25-012025-040022-B	<1
District of Columbia International School	WS-040-027	Classroom Faucet	2	In classroom 2A12			WF-012025-040027-09	N/A	FT-FY25-012025-040027-A	Non-operational	FT-FY25-012025-040027-B	Non-operational
District of Columbia International School	WS-040-029	Classroom Faucet	2	In classroom 2A11			WF-012025-040029-09	N/A	FT-FY25-012025-040029-A	Non-operational	FT-FY25-012025-040029-B	Non-operational
District of Columbia International School	WS-040-031	Food Prep Sink	Basement	In kitchen CA26		Left	WF-012025-040031-09	6/23/2025	FT-FY25-012025-040031-A	<1	FT-FY25-012025-040031-B	<1
District of Columbia International School	WS-040-032	Food Prep Sink	Basement	In kitchen CA26		Right	WF-012025-040032-10	6/23/2025	FT-FY25-012025-040032-A	<1	FT-FY25-012025-040032-B	<1
District of Columbia International School	WS-040-033	Ice Maker	Basement	In kitchen CA26			WF-012025-040033-09	6/23/2025	FT-FY25-012025-040033-A	<1	FT-FY25-012025-040033-B	<1
District of Columbia International School	WS-040-034	Cooler	Basement	In hallway adjacent to girls restroom	Low	Left	WF-012025-040034-09	N/A	FT-FY25-012025-040034-A	Non-operational	FT-FY25-012025-040034-B	Non-operational
District of Columbia International School	WS-040-035	Bottle Filler	Basement	In hallway adjacent to girls restroom	High	Left	WF-012025-040035-09	N/A	FT-FY25-012025-040035-A	Non-operational	FT-FY25-012025-040035-B	Non-operational
District of Columbia International School	WS-040-036	Cooler	Basement	In hallway adjacent to girls restroom	High	Right	WF-012025-040036-09	N/A	FT-FY25-012025-040036-A	Non-operational	FT-FY25-012025-040036-B	Non-operational
District of Columbia International School	WS-040-037	Break Room	2	In break room 2A03			WF-012025-040037-09	N/A	FT-FY25-012025-040037-A	Non-operational	FT-FY25-012025-040037-B	Non-operational